



Location Code: 042-K1614531

Contact: Ryan Stock

Contact Address: 1700 W MCKINNEY BUTTE RD

SISTERS, OR 97759-3118

Phone:

Email: ryan.stock@sisters.k12.or.us

Property Evaluated: Sisters High School (Educational)

1700 W MCKINNEY BUTTE RD

SISTERS, OR 97759-3118

Description: Fire Alarm (Fire Alarm)

Company: Watchdog Security

Address: 63043 Lower Meadow Dr., Suite 150

Bend, OR 97701

Company Phone: 541-617-6199

Company Fax: 541-617-6126

Inspector: Anthony Serna

5398LEA

Date of Work: 7/29/2020

Frequency: Annual

Attached Files

There are no attachments for this submission

Deficiency Summary

Please refer to the Deficiency Summary located on applicable Fire Alarm Supplementary Forms for additional deficiency details.

General Comments

There are no general comments for this submission



Watchdog Security

63043 Lower Meadow Dr., Suite 150

Bend, OR 97701 Phone: 541-617-6199

4. System Information

Other, if required:

Form for Inspection, Testing and Maintenance of Fire Alarms and Signaling Systems

Separate forms are available for inspection, testing, and maintenance of the rest of the fire protection system of which the fire alarms and signaling systems are a part. More frequent inspection, testing, and maintenance may be necessary depending on the conditions of the occupancy and the water supply. Notes:

- All questions are to be answered Yes, No, or Not Applicable. All "No" answers are to be explained in the *Comments* for this form. Refer to NFPA-72 for specific inspection frequency requirements

۷,	for the different components.	requency requirements
Th	e work covered on this form is (select	Annual
on		
	ite of Work	7/29/2020
mo	l responses refer to the current work (inspec iintenance) performed on this date. Property Information	ction, testing and
O	vner:	
	an Stock	
-	vner's Phone Number:	
	vner's Address:	070 07770 0110
	00 W MCKINNEY BUTTE RD, SISTERS	, OR, 97759-3118
	operty Being Evaluated:	
	sters High School (Educational)	
	operty Address:	OD 07750 2110
	00 W MCKINNEY BUTTE RD, SISTERS	, OR, 97/39-3118
	sembly Description: e Alarm (Fire Alarm)	
-	Owner's Section	
	Are the fire alarms and signaling systems	
	service?	✓ Yes □ No
	Have fire alarms and signaling systems nained in service since the last inspection?	✓ Yes □ No
	Was the system (of which the fire alarm	
an	was the system (or which the the than did signaling systems are a part) free of tuation of devices or alarms since the last spection?	☐ Yes ✓ No
D. av all so	The required record documents are allable and include the current revisions of fire alarm software and the revisions of tware of any systems with which the fire arm software interfaces?	☐ Yes 🗹 No
Ov	vner or Representative	Ryan Stock
Sig	gnature	No Signature Availab
Da	te	7/29/2020
3.	Monitoring Information	
Mo	onitoring organization:	Rapid Response
Ac	ldress:	400 W Division
10.1		Syracuse, NY 13204
	one:	800-932-3822
Fa		315-479-9573
	nail:	dataentry@rrms.com
	count number:	K1614531
	one line 1: one line 2:	X
		N Padio
	eans of transmission:	Radio
	tity to which alarms are retransmitted:	X
rn	one:	X

4.1 Control Unit:	
Manufacturer:	Simplex-Grinnell
Model number:	4010
4.2 Software and Firmware Revision number:	?
4.3 System Power:	
4.3.1 Primary (Main) Power:	
Nominal voltage:	120vac
Amps:	98
Location:	FACP
Overcurrent protection type:	Breaker
Amps:	20
Disconnecting means location:	Panel 2EL-1
4.3.2 Secondary Power:	
Type:	Battery
Location:	Panel
Battery type (if applicable):	☐ Lead-acid ☐ Nickel- cadmium ☐ Primary (dry cell) ✓ Sealed lead-acid
Calculated capacity of batteries to drive the sy	stem:
In standby mode (hours): In alarm mode (minutes):	
5. Notifications Made Prior To Testing	11

Contact Time Monitoring **RRMS** 7:00 organization: Building Ryan Stock 7:00 management: Building occupants: Yes 7:00 Authority Having 911 7:00 Jurisdiction:



Watchdog Security

63043 Lower Meadow Dr., Suite 150 Bend, OR 97701

Phone: 541-617-6199

6. Testing Results

6.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Results
Control unit	✓ Yes □ No	✓ Yes □ No	✓ Pass ☐ Fail ☐ N/A
Lamps/LEDs/L CDs	✓ Yes No	✓ Yes No	✓ Pass □ Fail □ N/A
Fuses	✓ Yes No	✓ Yes 🗆 No	Pass Fail
Trouble signals	✓ Yes No	✓ Yes 🗆 No	Pass Fail
Disconnect switches	✓ Yes No	✓ Yes No	✓ Pass ☐ Fail ☐ N/A
Ground-fault monitoring	✓ Yes No	✓ Yes □ No	Pass Fail
Supervision	✓ Yes No	✓ Yes 🗆 No	✓ Pass ☐ Fail ☐ N/A
Local annunciator	✓ Yes 🗆 No	✓ Yes 🗆 No	✓ Pass ☐ Fail ☐ N/A
Remote annunciators	✓ Yes No	✓ Yes No	✓ Pass □ Fail □ N/A
Remote power panels	✓ Yes 🗆 No	✓ Yes 🗆 No	✓ Pass ☐ Fail ☐ N/A
Other:	Yes No	☐ Yes ☐ No	□ Pass □ Fail □ N/A

6.2 Secondary Power

Description	Visual Inspection	Functional Test	Results
Battery condition	✓ Yes No	✓ Yes □ No	✓ Pass ☐ Fail ☐ N/A
Load voltage	✓ Yes □ No	✓ Yes □ No	✓ Pass ☐ Fail ☐ N/A
Discharge test	✓ Yes □ No	✓ Yes □ No	Pass Fail
Charger test	✓ Yes No	✓ Yes No	Pass Fail
Remote panel batteries	✓ Yes No	✓ Yes □ No	Pass Fail

6.3 Alarm and Supervisory Alarm Initiating Device

Complete supplementary device test form for all initiating devices.

6.4 Notification Appliances

Complete supplementary appliance test form for all notification appliances.

6.5 Interface Equipment

Complete supplementary interface component test form for all interface components.

Circuit Interface / Signaling Line Circuit Interface / Fire Alarm Control Interface

6.6 Supervising Station Monitoring

Description	Yes/No	Time (sec)	Results
Alarm signal	✓ Yes □ No	7	Pass Fail N/A
Alarm restoration	✓ Yes No	9	Pass Fail
Trouble signal	✓ Yes No	11	Pass Fail N/A
Trouble restoration	✓ Yes □ No	6	Pass Fail
Supervisory signal	✓ Yes □ No	12	Pass Fail N/A
Supervisory restoration	✓ Yes □ No	5	Pass Fail N/A

6.7 Public Emergency Alarm Reporting System

Description	Yes/No	Time (seconds)	Results
Alarm signal	☐ Yes ☐ No		□ Pass □ Fail ☑ N/A
Alarm restoration	☐ Yes ☐ No		☐ Pass ☐ Fail ☑ N/A
Trouble signal	☐ Yes ☐ No		□ Pass □ Fail ☑ N/A
Trouble restoration	☐ Yes ☐ No		□ Pass □ Fail ☑ N/A
Supervisory signal	☐ Yes ☐ No		□ Pass □ Fail ☑ N/A
Supervisory restoration	☐ Yes ☐ No		□ Pass □ Fail ☑ N/A

7. Notifications That Testing Is Complete

	Contact	Time
Monitoring organization:	RRMS	4:00
Building management:	Ryan Stock	4:00
Building occupants:	Yes	4:00
Authority Having Jurisdiction:	911	4:00
Other, if required:		

8. System Restored To Normal Operation

Date: 7/29/2020
Time: 4:00

9. Comments

Any "No" answers, test failures or other problems found with the fire alarm system must be explained using the comment specific for each question. Additional comments can be added here.

Please see the summary section at the top of the form for the comments.



Watchdog Security

63043 Lower Meadow Dr., Suite 150

Bend, OR 97701 Phone: 541-617-6199

10. Inspector's Information

Inspected By

Anthony Serna

I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested at this time was left in operating condition upon completion of this inspection except as noted in the *Comments*. This system as specified herein has been inspected and tested according to NFPA 72, 2013 edition, Chapter 14.

Signature of Inspector

Date

7/29/2020

Fire Alarm Supplementary Form



Location Code: 042-K1614531

Contact: Ryan Stock

Contact Address: 1700 W MCKINNEY BUTTE RD

SISTERS, OR 97759-3118

Phone:

Email: ryan.stock@sisters.k12.or.us

Property Evaluated: Sisters High School (Educational)

1700 W MCKINNEY BUTTE RD

SISTERS, OR 97759-3118

Description: Fire Alarm Supplement (Fire Alarm Supplement)

Bend, OR 97701

Company: Watchdog Security

Address: 63043 Lower Meadow Dr., Suite 150

Company Phone: 541-617-6199

Company Fax: 541-617-6126

Inspector: Anthony Serna 5398LEA

Date of Work: 7/27/2020

Frequency: Annual

Attached Files

There are no attachments for this submission

Deficiency Summary

Status: Open

Severity: Impairment

Deficiency for Device Type: STROBE, Address: NAC, Location: ART ROOM 602.

STROBE NOT FLASHING

Status: Open

Severity: Impairment

Deficiency for Device Type: STROBE, Address: NAC, Location: WRESTLING/ROCK CLIMBING GYM.

STROBE NOT FLASHING

General Comments

There are no general comments for this submission



Fire Alarm Supplementary Form

Account Information	Date of Work	The work covered on this form is (select one):
	7/27/2020	Annual

Facility Name: Proper Sisters High School Educat	Property Type: Educational	Location Code: 042-K1614531
Service Address: 1700 W MCKINNEY BUTTE RD, SISTERS, OR, 97759-3118		
Owner: Ryan Stock		Owner's Phone:
Owner's Address: 1700 W MCKINNEY BUTTE RD, SISTERS, OR, 97759-3118		

Legend				
PS - Pull Station	SD - Smoke Detector	DD - Duct Detector	MM - Monitor Module (Ansul, temp, CO, etc)	CO, etc)
CM - Control Module	WF - Waterflow	TS - Tamper Switch	HD - Heat Detector	SC - Signal/Sounder Control
Other	SPKR - Speakers	STROBE - Strobes	HORN - Horns/Horn-Strobes	BATT - Batteries

Type		Total	Tested	Not Tested	Passed	Failed	Type			Total	Tested	Not Tested	Passed	Failed
DD		40	39	1	39	0	HD			3	3	0	3	0
MM		2	2	0	2	0	PS			22	22	0	22	0
SD		103	103	0	103	0	STROBE	3E		2	2	0	0	2
TS		9	9	0	9	0	WF			3	3	0	3	0
Type	Address	Location		Notes			Fre	Frequency	Last Tested	Test Results	Comments	nts		
HD	M1-1	Initiating - Mechanical Room 537	nical Room				Anı	Annual	7/27/2020	Pass				
TS	M1-2	Initiating - Mechanical Room 537 OS&Y	nical Room				Anı	Annual	7/27/2020	Pass				
TS	M1-2	Initiating - Mechanical Room 537 Butterfly Valve	nical Room /e				Anı	Annual	7/27/2020	Pass				
TS	M1-2	Initiating - Mechanical Room 537 Butterfly Valve	nical Room				Anı	Annual	7/27/2020	Pass				
TS	M1-2	Initiating - Mechanical Room 537 Butterfly Valve	nical Room ve				Anı	Annual	7/27/2020	Pass				
TS	M1-2	Initiating - Mechanical Room 537 Butterfly Valve	nical Room ve				Anı	Annual	7/27/2020	Pass				





***************************************	***************************************			***************************************	-	
Type	Address	Location	Notes	Frequency	Last Tested	Test Results Comments
SD	M1-31	Initiating - Performance Gym 400		Annual	7/27/2020	Pass
SD	M1-32	Initiating - East Entry to Performance Gym		Annual	7/27/2020	Pass
SD	M1-33	Initiating - West Side of Sliding Fire Door		Annual	7/27/2020	Pass
SD	M1-34	Initiating - East Side of Sliding Fire Door		Annual	7/27/2020	Pass
SD	M1-35	Initiating - Circulation 500		Annual	7/27/2020	Pass
SD	M1-36	Initiating - Circulation 143		Annual	7/27/2020	Pass
SD	M1-38	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-39	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-40	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-41	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-42	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-43	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-44	Initiating - Circulation 134		Annual	7/27/2020	Pass
SD	M1-45	Initiating - Circulation 134		Annual	7/27/2020	Pass
SD	M1-46	Initiating - Circulation 231		Annual	7/27/2020	Pass
SD	M1-47	Initiating - Circulation 231		Annual	7/27/2020	Pass
SD	M1-48	Initiating - Circulation 231		Annual	7/27/2020	Pass
SD	M1-49	Initiating - Circulation 231		Annual	7/27/2020	Pass
SD	M1-50	Initiating - Circulation 231		Annual	7/27/2020	Pass
SD	M1-51	Initiating - Circulation 231		Annual	7/27/2020	Pass
PS	M1-52	Initiating - Circulation 231		Annual	7/27/2020	Pass
SD	M1-53	Initiating - Plaza 232		Annual	7/27/2020	Pass
SD	M1-54	Initiating - Plaza 232		Annual	7/27/2020	Pass
SD	M1-55	Initiating - Plaza 240		Annual	7/27/2020	Pass
SD	M1-56	Initiating - Plaza 240		Annual	7/27/2020	Pass
SD	M1-57	Initiating - Student Store 133		Annual	7/27/2020	Pass
SD	M1-58	Initiating - Business 131		Annual	7/27/2020	Pass
SD	M1-59	Initiating - Business 131		Annual	7/27/2020	Pass
SD	M1-60	Initiating - Circulation 128		Annual	7/27/2020	Pass
SD	M1-61	Initiating - Circulation 128		Annual	7/27/2020	Pass
SD	M1-62	Initiating - Circulation 215		Annual	7/27/2020	Pass
SD	M1-63	Initiating - Circulation 215		Annual	7/27/2020	Pass
SD	M1-64	Initiating - Circulation 215		Annual	7/27/2020	Pass



Tuno	Adden	- Poortion	Notes	Francisco	I act Tactad	
SD	M1-65	Initiating - Circulation 215		Annual	7/27/2020	Pass
SD	M1-66	Initiating - Circulation 215		Annual	7/27/2020	Pass
SD	M1-67	Initiating - Circulation 220		Annual	7/27/2020	Pass
SD	M1-68	Initiating - Circulation 215		Annual	7/27/2020	Pass
SD	M1-69	Initiating - Vestibule 216		Annual	7/27/2020	Pass
PS	M1-70	Initiating - Vestibule 216		Annual	7/27/2020	Pass
SD	M1-71	Initiating - Plaza 210		Annual	7/27/2020	Pass
SD	M1-72	Initiating - Plaza 210		Annual	7/27/2020	Pass
SD	M1-73	Initiating - Plaza 203		Annual	7/27/2020	Pass
SD	M1-74	Initiating - Plaza 203		Annual	7/27/2020	Pass
SD	M1-75	Initiating - Circulation 128 South		Annual	7/27/2020	Pass
PS	M1-76	Initiating - Circulation 128 South		Annual	7/27/2020	Pass
SD	M1-77	Initiating - Circulation 128		Annual	7/27/2020	Pass
SD	M1-78	Initiating - Circulation 129		Annual	7/27/2020	Pass
SD	M1-79	Initiating - Circulation 129		Annual	7/27/2020	Pass
SD	M1-80	Initiating - Circulation 129		Annual	7/27/2020	Pass
SD	M1-81	Initiating - Commons 101 Southeast	Did not drop reception firefly door.	Annual	7/27/2020	Pass
SD	M1-82	Initiating - Waiting 102	Did not drop reception firefly door.	Annual	7/27/2020	Pass
PS	M1-83	Initiating - Principals Secretary		Annual	7/27/2020	Pass
PS	M1-84	Initiating - Commons 101		Annual	7/27/2020	Pass
PS	M1-85	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-86	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-87	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-88	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-89	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-90	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-91	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-92	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-93	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-94	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-95	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-96	Initiating - Commons 101		Annual	7/27/2020	Pass
SD	M1-97	Initiating - Commons 101		Annual	7/27/2020	Pass



	Pass	7/29/2020	Annual		Initiating - Dish Washing Room 535	M1-135	HD
	Pass	7/27/2020	Annual		Initiating - Exit Passage 702	M1-130	PS
	Pass	7/27/2020	Annual		Initiating - Media Center 145	M1-129	SD
	Pass	7/27/2020	Annual		Initiating - Media Center 145	M1-128	SD
	Pass	7/27/2020	Annual		Initiating - Media Center 145	M1-127	SD
	Pass	7/27/2020	Annual		Initiating - Media Center 145	M1-126	PS
	Pass	7/27/2020	Annual		Initiating - Conference Room 2/152	M1-125	SD
	Pass	7/27/2020	Annual		Initiating - Media Center 145	M1-124	SD
	Pass	7/27/2020	Annual		Initiating - Media Center 145	M1-123	SD
	Pass	7/27/2020	Annual		Initiating - Media Center 145	M1-122	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 144	M1-121	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 144	M1-120	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 144	M1-119	SD
	Pass	7/27/2020	Annual		Initiating - Exit Passage 702	M1-118	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 600	M1-117	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 600	M1-116	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 600	M1-115	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 600	M1-114	SD
	Pass	7/27/2020	Annual		Initiating - Art 601 Exit	M1-113	PS
	Pass	7/27/2020	Annual		Initiating - Circulation 600	M1-112	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 600	M1-111	PS
	Pass	7/27/2020	Annual		Initiating - Work Area 637 Exit	M1-109	PS
	Pass	7/27/2020	Annual		Initiating - Band 632	M1-108	PS
	Pass	7/27/2020	Annual		Initiating - Vestibule 631	M1-107	PS
	Pass	7/27/2020	Annual		Initiating - Choir 218	M1-106	PS
	Pass	7/27/2020	Annual		Initiating - Circulation 626	M1-105	SD
	Pass	7/27/2020	Annual		Initiating - Work Room 627 Exit	M1-104	PS
	Pass	7/27/2020	Annual		Initiating - Stage 701 Exit	M1-103	PS
	Pass	7/27/2020	Annual	in circ 143	Initiating - Circulation 205	M1-101	PS
	Pass	7/27/2020	Annual		Initiating - Circulation 205	M1-100	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 205	M1-99	SD
	Pass	7/27/2020	Annual		Initiating - Circulation 205	M1-98	SD
Comments	Test Vesuits	Last rested	Fieducticy	110163	Processor		



Type	Address		Notes	Frequency	Last Tested	Test Results	Comments
DD	M1-136	Initiating - Return Plenum AHU 1&2	Attic	Annual	7/28/2020		
DD	M1-137	Initiating - West Mechanical Room AHU 12	Attic	Annual	7/28/2020	Pass	
DD	M1-138	age Room 801	Attic	Annual	7/28/2020	Pass	
DD	M1-139	Initiating - Mechanical Room 803 North BC 3	Attic	Annual	7/28/2020	Pass	
DD	M1-140	Initiating - Mechanical Room 803 AHU 9	Attic	Annual	7/28/2020	Pass	
DD	M1-141	Initiating - Mechanical Room 803 AHU 8	Attic	Annual	7/28/2020	Pass	
DD	M1-142	Initiating - Mechanical Room 803 South AHU 4	Attic	Annual	7/28/2020	Pass	
DD	M1-143	Initiating - Mechanical Room 803 South AHU 14	Attic	Annual	7/28/2020	Pass	
DD	M1-144	Initiating - Mechanical Auditorium AHU 7	Attic	Annual	7/28/2020	Pass	
DD	M1-157	Room	Attic	Annual	7/28/2020	Pass	
MM	M1-162	Initiating - Ansul Class 1 Hood North		Annual	7/28/2020	Pass	
MM	M1-163	Initiating - Ansul Class 1 Hood South		Annual	7/28/2020	Pass	
DD	M1-166	Initiating - Physical Science 226		Annual	7/29/2020	Pass	
DD	M1-167	Initiating - Physical Science 226		Annual	7/29/2020	Pass	
DD	M1-168	Initiating - Circulation 231		Annual	7/28/2020	Pass	
DD	M1-169	Initiating - Circulation 231		Annual	7/28/2020	Pass	
DD	M1-170	Initiating - Circulation 231		Annual	7/28/2020	Pass	
DD	M1-171	Initiating - Circulation 231		Annual	7/28/2020	Pass	
DD	M1-172	Initiating - Biology 221		Annual	7/29/2020	Pass	
DD	M1-173	Initiating - Biology 221		Annual	7/29/2020	Pass	
DD	M1-174	Initiating - Biology 221		Annual	7/29/2020	Pass	
DD	M1-176	Initiating - Physical Science 222		Annual	7/29/2020	Pass	
DD	M1-177	Initiating - Physical Science 222		Annual	7/29/2020	Pass	
DD	M1-178	Initiating - Physical Science 222		Annual	7/29/2020	Pass	



7			Notice		Took Tookad		
DD	M1-179	- Physical Science		Annual		Pass	(
DD	M1-180		Inaccessible.		7/30/2019	N/A	
DD	M1-181	Initiating - Attendance Reception 123	Tamper tool needed along with smoke and air	Annual	7/29/2020	Pass	
DD	M1-182	chanical Room	Attic	Annual	7/28/2020	Pass	
DD	M1-184	Initiating - Mechanical Room 800 AHU 3	Attic	Annual	7/29/2020	Pass	
DD	M1-185	Initiating - Mechanical Room 800 AHU 1&2	Attic	Annual	7/28/2020	Pass	
DD	M1-186	Initiating - FSD CIRCLE 702 EXIT		Annual	7/28/2020	Pass	
DD	M1-187	Initiating - FSD Circle 702 Exit	Located in attic, in south hall, near the theatre	Annual	7/28/2020	Pass	
DD	M1-188	Initiating - FSD Circle 702 Exit	d in attic, in south hall, near the	Annual	7/29/2020	Pass	
DD	M1-190	Initiating - Mechanical Room 804 FSD AHU 7	Attic	Annual	7/28/2020	Pass	
DD	M1-191	Initiating - Mechanical Room 803 FSD AHU 4	Attic	Annual	7/28/2020	Pass	
DD	M1-192	Initiating - Mechanical Room 803 BC 4	Attic	Annual	7/28/2020	Pass	
DD	M1-193	Initiating - Mechanical Room 803 FSD AHU 8	Attic	Annual	7/28/2020	Pass	
DD	M1-194	Initiating - Mechanical Room 801 BC 2	Attic	Annual	7/28/2020	Pass	
DD	M1-195	Initiating - Theater FSD AHU		Annual	7/28/2020	Pass	
DD	M1-196	Initiating - Theater FSD AHU		Annual	7/28/2020	Pass	
DD	M1-197	Initiating - Shop 637 AHU 10	Wood shop	Annual	7/29/2020	Pass	
WF	M1-198	Initiating - Flow Switch Mechanical 537		Annual	7/27/2020	Pass	
WF	M1-198	Initiating - Flow Switch Mechanical 537		Annual	7/27/2020	Pass	
WF	M1-198	Initiating - Flow Switch Mechanical 537		Annual	7/27/2020	Pass	
DD	M1-199	Initiating - FSD Circle 129 Above		Annual	7/29/2020	Pass	



Bend, OR 97701 63043 Lower Meadow Dr., Suite 150 Watchdog Security

Phone: 541-617-6199

Notification -	STROBE NAC Notification - ART ROOM 602	SD M1-209 Initiating - Stage Roll Up Door Room 701	HD M1-208 Initiating - Backstage Work Room Rm627	TS M1-207 Initiating - Fire Pump	Type Address Location
Notification - WRESTLING/ROCK	ART ROOM	ige Roll Up)1	ekstage Work	e Pump	
			Drops fire day		Notes
Annual	Annual	Annual	Annual	Annual	Frequency
7/29/2020	7/29/2020	7/27/2020	7/29/2020 Pass	7/27/2020	Last Tested
æ.	Fail	Pass	Pass	Pass	Last Tested Test Results Comments
Impairment, STROBE NOT FLASHING	Impairment, STROBE NOT FLASHING				Comments

Comments

Please see the summary section at the top of the form for the comments. Inspector's Information Any deficiencies or other problems found with the devices must be explained using the comment specific for each device. Additional comments can be added here.

Antinony Serna
I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested at this time was left in operating condition upon completion of this inspection except as noted in the Comments.

Signature of Inspector Inspected By

Date

Anthony Serna

7/27/2020

©2014 FormLink Systems, Inc., Fire Alarm Supplement v1.1